

Primm, Mark

COMED EXHIB 154

**From:** Sobodas, William E.  
**Sent:** Thursday, December 20, 2007 1:10 PM  
**To:** Primm, Mark  
**Subject:** FW: ICC Docket no. 06-0726 Kenneth Bourkland 6N347 Old Homestead Rd, St Charles  
**Importance:** High

Mark,

I went back out today and took some more measurements on the 3/C 266al secondary behind 6N347 Old Homestead Rd. I actually found a area where the secondary was 11' 7" which is 2" shorter than the original 11' 9". The heights of the primary and secondary attachments at the pole to the North is as follows: Pri attached @ 23' 4" and the sec. attached @ 19' 8". The pole to the south is a taller pole and the primary and secondary are well within our limits. Please contact me if you have any questions.

Thanks,

Bill

-----Original Message-----

**From:** Sobodas, William E.  
**Sent:** Wednesday, December 12, 2007 7:32 AM  
**To:** Primm, Mark  
**Subject:** RE: ICC Docket no. 06-0726 Kenneth Bourkland 6N347 Old Homestead Rd, St Charles

Mark,

I went out to this site yesterday and gathered the information that was requested. The span behind the above address is single phase with 3/C 266Al secondary on it. The primary wire looks to be 1/0 ALA bare and is approximately 18' 3" above grade. The secondary cables were 11' 9" above grade at the lowest point. The primary is tied into a ridge pin on the pole to the north and that pole is a 30-4. The grade is actually lower on that end. The primary to the south is tied into a insulator on a small alley arm on a 35-4 pole. This pole also has transformer 3D9 on it. This is a 12kv area so the primary is 7.2kv. According to the pole records, the pole to the north was installed in 1963 and the pole to the south 1972. Please let me know if you need any other information. I do have a few pictures of the area if you want them.

Bill

-----Original Message-----

**From:** Primm, Mark  
**Sent:** Monday, December 10, 2007 1:38 PM  
**To:** Sobodas, William E.  
**Subject:** FW: ICC Docket no. 06-0726 Kenneth Bourkland 6N347 Old Homestead Rd, St Charles

Mark Primm  
 Emergent Work Supervisor  
 West Central C&M  
 815-600-1795

06-0726  
 CWF 4  
 1/17/08 P.W

1/16/2008

-----Original Message-----

**From:** Parise, John Jr

**Sent:** Thursday, December 06, 2007 2:55 PM

**To:** Daniels, Yvette D.; Primm, Mark

**Subject:** FW: ICC Docket no. 06-0726 Kenneth Bourkland 6N347 Old Homestead Rd, St Charles

Yvette/Mark: Would you please give me a call asap regarding this customers issue...Thanks!

***Have A Safe Day...***

*John Parise*

Senior Administrator

Regulatory Strategies and Services

312 394 3866

312 394 8693 Fax

john.parise@exeloncorp.com

-----Original Message-----

**From:** Parise, John Jr

**Sent:** Thursday, December 06, 2007 2:52 PM

**To:** 'mglawoffices@aol.com'

**Cc:** Miceli, Louis J. (PSEG); Adams, Thomas L.; Daniels, Yvette D.

**Subject:** RE: ICC Docket no. 06-0726 Kenneth Bourkland 6N347 Old Homestead Rd, St Charles

Mark: We have the two witnesses...well maybe 3 now!

Tom Adams - Will be addressing the clearance issue...he is ComEd's subject matter expert regarding line clearances

Paul Miceli - Will be addressing the tree trimming issue...he is a Vegetation Project Lead for ComEd

TBD - Will address Greg Rockrohr's questions of ComEd from his testimony...

\* The date ComEd initially installed the distribution facilities that are the subject of this complaint.

\* An accurate description of each conductor that it has installed in its right-of-way affecting Complainant's property, including the voltage.

\* The minimum ground clearance of its insulated secondary conductor that is the subject of the complaint.

\* The minimum ground clearance of its primary conductor that appears to be installed above the insulated secondary conductor that is the subject of the complaint.

**Have A Safe Day...**

John Parise  
Senior Administrator  
Regulatory Strategies and Services  
312 394 3866  
312 394 8693 Fax  
john.parise@exeloncorp.com

-----Original Message-----

**From:** mlglawoffices@aol.com [mailto:mlglawoffices@aol.com]  
**Sent:** Thursday, December 06, 2007 2:21 PM  
**To:** Parise, John Jr  
**Subject:** Fwd: ICC Docket no. 06-0726

John---

Add this to the list. Mark

-----Original Message-----

**From:** Javaherian, Arshia <javahera@icc.illinois.gov>  
**To:** @ Goldstein, Mark <MLGLAWOFFICES@aol.com>  
**Cc:** Javaherian, Arshia <javahera@icc.illinois.gov>  
**Sent:** Thu, 6 Dec 2007 2:13 pm  
**Subject:** ICC Docket no. 06-0726

Mark,

I just received your response to my DR requests. Thank you. I was wondering when I can expect a response to question 2: a list of witnesses and the areas they will be addressing.

Thank you,

**Arshia Javaherian**  
Office of General Counsel  
Illinois Commerce Commission  
312-793-8822  
[javahera@icc.illinois.gov](mailto:javahera@icc.illinois.gov)

\*\*\*\*\*  
This e-mail message may contain privileged, confidential and/or proprietary information intended only for the person(s) named. If you are not the intended recipient, please destroy this message, and any attachments, and notify the sender by return e-mail. If you are not the intended recipient(s), or the employee or agent responsible for delivering the message to the intended recipient(s), you are hereby notified that any dissemination, disclosure or copying of this communication is strictly prohibited.  
\*\*\*\*\*

More new features than ever. Check out the new [AOL Mail!](#)